Existing Roof Party Wall Line with No Compartmentation





- •Timber battens and combustible felt pass over the party wall with no fire breaks
- •The voids between the battens are not fire stopped allowing spread of fire
- •The eaves void (behind the soffit and fascia boards) is continuous over the party wall without cavity barriers